Ingersoll Rand

IRN 15-30 kW (20-40 HP)



⚠ WARNING

Variable frequency drive to be serviced by trained personnel only. After switching off the machine at its local isolator, WAIT AT LEAST 15 MINUTES for the capacitors to fully discharge before removing the drive cover. With caution, verify DC bus voltage is zero before servicing. Proceed with caution.

⚠ ADVERTÊNCIA

O módulo conversor de freqüência somente deve ser mantido por um técnico capacitado. Depois de desligar o equipamento no seu disjuntor local, ESPERE PELO MENOS 15 MINUTOS para que se descarreguem completamente os capacitores antes da remossão das portas de proteção do módulo. Antes da manutenção, verifique com cautela se a tensão DC bus está em zero. Prossiga com prudência.

⚠ ADVERTENCIA

El módulo conversor de frecuencia deberá somente ser mantenido por un técnico capacitado. Después de desconectar el equipo en su aislador local, ESPERE 15 MINUTOS COMO MÍNIMO para que se descarguen por completo los condensadores antes de quitar la cubierta potectora del módulo. Antes de prover matenimiento, verifique con precaución se el voltage DC Bus está en zero. Prosiga con prudencia.

C.C.N. : 80442932
REV. : A
DATE : OCTOBER 2006

http://air.irco.com